

FIRE SERVICES ORDINANCE (Chapter 95)

ORDER MADE BY THE REGISTERED FIRE SERVICE
INSTALLATION CONTRACTORS DISCIPLINARY BOARD

It is hereby notified that a Disciplinary Board appointed by the Chief Executive under regulation 9 of the Fire Service (Installation Contractors) Regulations (the 'Regulations'), subsidiary legislation of the Fire Services Ordinance, Chapter 95, Laws of Hong Kong, was satisfied after a due inquiry held on 23 January 2024 in accordance with regulation 10 of the Regulations, that FU Chi-tung trading as Grand Hope Fire Plumbing Electrical Engineering Co., being a Class 1 and Class 2 registered Fire Service Installation Contractor, was guilty of improper conduct or negligence in the installation, maintenance, repair or inspection of fire service installation or equipment, in that, during an annual inspection of fire service installation and equipment on 1 June 2022 at Villa Rosa, 88 Red Hill Road, Tai Tam, Hong Kong, the contractor failed to ensure the pressure and flow of the water from the street fire hydrant system comply with the requirement imposed by the Fire Service Department i.e. flow gauge was not utilized to test the flow rate of the street fire hydrant system, such that its continued inclusion in the register of fire service installation contractors will be prejudicial to the due administration of the Fire Services Ordinance.

It is further notified that pursuant to regulation 10(2)(a) of the Regulations, the said Disciplinary Board ordered that FU Chi-tung trading as Grand Hope Fire Plumbing Electrical Engineering Co. be removed from the register of fire service installation contractors in Class 1 and Class 2 for a period of TWO MONTHS, which order will take effect from 23 February 2024 to 22 April 2024.

CHAN Man-hon, Steven *Chairman, Registered Fire Service
Installation Contractors Disciplinary Board*