

G.N. 2880

ELECTRICITY ORDINANCE (Chapter 406)

It is hereby notified that in accordance with section 37 of the Electricity Ordinance (Chapter 406) ('the Ordinance'), I was satisfied on evidence and decided that Chui Hing Development Co had failed to comply with Regulation 4(2) of the Electricity (Wiring) Regulations made under Section 59 of the Ordinance in that Chui Hing Development Co, being a registered electrical contractor (Registration No.: 011449), on or about 31 January 2021, failed to provide supplementary bonding for the metallic basin and water pipes at M/F, 4 Fu Hing Street, Sheng Shui, New Territories, and hence failed to ensure that the fixed electrical installation was designed, constructed, installed and protected so as to prevent danger.

It is further notified that in accordance with section 36(1)(b)(i) of the Ordinance, I have reprimanded Chui Hing Development Co.

12 May 2023

CHU Kei-ming, Barry for *Director of Electrical and Mechanical Services*