

G.N. 5665

ELECTRICITY ORDINANCE (Chapter 406)

It is hereby notified that in accordance with section 37 of the Electricity Ordinance (Chapter 406) ('the Ordinance'), I was satisfied on evidence and decided that Lik Wang Eng. (HK) Limited had failed to comply with regulation 21(1) of the Electricity (Wiring) Regulations made under section 59 of the Ordinance in that Lik Wang Eng. (HK) Limited, being a registered electrical contractor (Registration No.: 020378), on or about 16 November 2021, was responsible for the periodic inspection, testing and certification work for the fixed electrical installation at On Fai Building, Nos. 30-40B Yuen Long On Hing Street, New Territories but failed to ensure that tests on the fixed electrical installation had been carried out with proper testing equipment.

It is further notified that in accordance with section 36(1)(b)(i) of the Ordinance, I have reprimanded Lik Wang Eng. (HK) Limited.

7 October 2022

CHU Kei-ming for *Director of Electrical and Mechanical Services*