

BUILDINGS ORDINANCE (Chapter 123)  
(Section 35)

SERVICE OF ORDER

In accordance with the proviso to section 35 of the Buildings Ordinance, I append a copy of an order together with the available particulars of the person to whom it is addressed as detailed below:—

Order by the Building Authority under section 24(1)  
of the Buildings Ordinance (Cap. 123)

Order No. : CUC/116-42/0015/14  
Our Ref. No : EB/4325/62/U03(CUC14)PT.III

Office of the Building Authority  
Buildings Department Headquarters,  
North Tower,  
West Kowloon Government Offices,  
11 Hoi Ting Road,  
Yau Ma Tei, Kowloon.

To : The Owner(s) of  
PORTION A ON 6TH FLOOR  
NO. 265 LAI CHI KOK ROAD KOWLOON,  
PORTION B ON 6TH FLOOR  
NO. 265 LAI CHI KOK ROAD KOWLOON,  
PORTION C ON 6TH FLOOR  
NO. 265 LAI CHI KOK ROAD KOWLOON and  
PORTION D ON 6TH FLOOR  
NO. 265 LAI CHI KOK ROAD KOWLOON

Date : 17 December 2021

Owner(s) of the premises at: **PORTION A ON 6TH FLOOR NO. 265 LAI CHI KOK ROAD KOWLOON, PORTION B ON 6TH FLOOR NO. 265 LAI CHI KOK ROAD KOWLOON, PORTION C ON 6TH FLOOR NO. 265 LAI CHI KOK ROAD KOWLOON and PORTION D ON 6TH FLOOR NO. 265 LAI CHI KOK ROAD KOWLOON** on (Lot Number) **N.K.I.L. 571 s.A R.P.**

It has been brought to my attention that the following building works have been carried out in or at the above premises:

- (i) conversion of the flat into sub-divided flats, including erection of partition wall(s), door(s) and metal gate(s), causing inadequate width of means of escape at corridor; and
- (ii) removal of the self-closing device of the fire rated door at the unit entrance.

2. For the said building works:

- (a) As a result of the building works at item (i) above, Regulation 41(1) of the Building (Planning) Regulations, which requires the building to be provided with such means of escape in case of emergency as required by the intended use of the building, has been contravened.
- (b) As a result of the building work at item (ii) above, Regulations 35 of the Building (Construction) Regulations, which requires the building to be designed and constructed so as to inhibit or provide adequate resistance to the spread of fire and smoke; and to maintain stability of the building in case of fire has been contravened.

3. In exercise of the powers vested in me under section 24(1) of the Buildings Ordinance, I hereby order you to :-

- (a) demolish the said building works described under item (i) above; and
- (b) reinstate the parts of the building so affected by the building works under items (i) to (ii) above in accordance with the plans approved by the Building Authority or otherwise to put an end to the contraventions of those provisions of the Buildings Ordinance.

Adequate precautionary measures to ensure public safety should be provided prior to and during the course of works.

4. You are required to commence the works ordered by me in paragraph 3 above within 90 days and complete such works within 180 days of the date of this order, all to the satisfaction of the Building Authority.

(KWOK Chun-man)

Building Surveyor/D1-3

for Building Authority

Note

- (1) Your attention is drawn to the provisions of sections 24(3), 24(4) and 33 of the Buildings Ordinance.
- (2) Should you wish to appeal against my Order, you may give notice of appeal to the Secretary to the Appeal Tribunal (Buildings) and the notice should be received by the Secretary not later than 21 days after the date of this Order (Address: Rooms 1005-06, 10/F, Wing On Kowloon Centre, 345 Nathan Road, Kowloon, Hong Kong and the fax number is 3579 4971). If you need further information, please refer to the covering letter together with a copy of this Order sent to you by registered mail or visit the Buildings Department's website ([www.bd.gov.hk](http://www.bd.gov.hk)).

The original copy of this order was posted upon a conspicuous part of the identified premises on its date of issue.

17 December 2021

CHAN Wai-ming *Chief Building Surveyor/D*  
for Building Authority